



These drawings are only intended as guidelines. Structural calculations and detailing should be provided for retaining walls.

Minimum allowable bearing capacity of formation is 25kN/sq. m (uniformly distributed) or 50kN/sq. m (triangularly distributed).

Weep holes must be provided for the draining of water behind the retaining wall.

Rev :	Remarks :	Drawn :	Date :
A	Issued drawing.		Dec. 2003
B	Change logo to TM	E. Farrugia	April 2014