



NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. THE MINIMUM DEPTH FROM THE TOP OF THE GRATING TO THE TOP OF THE GULLY OUTLET IS TO BE 750 WHEN THE CONNECTING PIPE IS UNDER A CARRIAGEWAY OR A HARD SHOULDER AND 600 ELSEWHERE.
3. PRECAST CONCRETE GULLIES AND COVER SLABS SHALL BE TO BS 5911 : PART 230
4. FOR DETAILS OF GULLY GRATING SEE RCD/500/16.
5. WHERE A GULLY HAS A TRAP THE STOPPERS SHALL COMPLY WITH THE REQUIREMENTS OF B.S. 5911: PART 2

Rev :	Remarks :	Drawn :	Date :	Title :
A	Issued drawing.		April 2003	
B	Change logo to TM	E. Farrugia	March 2014	