



NOTES :

1. THIS RCD IS ONLY TO BE USED IN ASSOCIATION WITH A UNIQUE STRUCTURAL DESIGN CARRIED OUT FOR THE HEADWALLS ON A PROJECT IN ACCORDANCE WITH RELEVANT DESIGN CODES AND SITE GROUND CONDITIONS.
2. ALL EXPOSED CONCRETE SURFACES FROM 100MM BELOW GROUND LEVEL TO BE CLASS F3 FINISH. ALL OTHER CONCRETE SURFACES TO BE CLASS F1 FINISH UNLESS OTHERWISE SPECIFIED.
3. REFER TO DRAINAGE LONGITUDINAL SECTIONS AND/OR DRAINAGE SCHEDULES FOR PIPE DIAMETER SIZES, INVERT LEVELS AND HEADWALLS HEIGHTS. MAXIMUM PIPE DIAMETER 300MM AND MAXIMUM HEADWALL HEIGHT (H) 2.3M.
4. HEADWALL WINGWALLS TO BE SLOPED WHERE APPROPRIATE AS SHOWN ON RCD/500/24.
5. HEADWALLS ARE SMALL HEADWALLS AS SPECIFIED IN THE METHOD OF MEASUREMENT SERIES 500 PARAGRAPH 35.

Rev :	Remarks :
A	Issued drawing.
B	Change logo to TM

Drawn :	Date :
	March 2003
E. Farrugia	March 2014

Title :