



Detail of Typical Bracket

Designation.

Designation for a cable bracket to support 5 cables is as follows:

RCD500/67/5Way

Various sized brackets can be fixed in trench, acc. to cable diameter and amount, therefore designation is to vary accordingly.

NOTES:

- * All brackets fabricated from mild steel flat bar.
- * Material size 50mm wide x 6mm thick.
- * Fixing holes 13mm Ø.
- * All edges are to be grinded smooth .
- * After fabricated, all brackets are to be hot dipped galvanised.
- * Equivalent rawlbolts are to be used when fixing.
- * All brackets are to be fabricated with 2 fixing holes.
- * This drawing is to be read in conjunction with drawings no: RCD500/65 and RCD500/68.
- * All dimensions are in mm.

Rev :	Remarks :	Drawn :	Date :
-	Issued drawing.	H.Galea	July 2009
A	Change Logo to TM	M.Borg	March 2010
B	Included Earth Cable Bracket at Top end of Bracket	H.Galea	Aug. 2012